# TEST CERTIFICATE

**Customer Name**

Dom Plays Sax

**Address**

**Company Name :**

Alan Freeman

**Tester Name :**

Alan

**Test Instrument Details**

**Make/Model :** SEAWARD

**Serial Number :** X20-0956

| No. | Date | Description | Serial No. | Location | Visual | Polarity | Earth Bond | | Class | Insulation | | Leakage | | Flash | | Load KVA | | Result | Retest |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 001 | 30/08/18 | IEC LEAD | 1 | | PASS | PASS | PASS | 00.04 | N/A | PASS | >99.99 | N/A | 0.00 | N/A | 0.00 | N/A | 0.00 | PASS | 29/08/2022 |
| 002 | 30/08/18 | ALESIS AMP | 2 | | PASS | N/A | PASS | 00.15 | N/A | PASS | >99.99 | PASS | 0.23 | N/A | 0.00 | PASS | <0.05 | PASS | 29/08/2022 |
| 003 | 30/08/18 | 40M EXT LEAD | 3 | | PASS | PASS | PASS | 00.95 | N/A | PASS | >99.99 | N/A | 0.00 | N/A | 0.00 | N/A | 0.00 | PASS | 29/08/2022 |
| 004 | 30/08/18 | MAC PSU | 4 | | PASS | N/A | N/A | | N/A | N/A | 0.00 | N/A | 0.00 | N/A | 0.00 | N/A | 0.00 | PASS | 29/08/2022 |